

2010 Consumer Confidence Report

Secondary Constituents

City of Sugar Land - RiverPark Public Water System # 790354

<i>CONSTITUENT</i>	<i>SECONDARY MAXIMUM CONTAMINANT LEVEL (MCL)</i>	<i>YEAR</i>	<i>RESULTS FOR SUGAR LAND - RIVERPARK PWS # 790354</i>
Aluminum	00.05 - 0.2 mg/L	2010	< 0.02 mg / L
Bicarbonate	<i>no MCL</i>	2008	242 mg / L
Calcium	<i>no MCL</i>	2010	41.3 mg / L
Chloride	250 mg/L	2008	40 mg / L
Copper	1.0 mg/L	2010	< 0.002 mg / L
Fluoride	2.0 mg/L	2008	0.35 mg / L
Iron	0.3 mg/L	2010	0.021 mg / L
Magnesium	<i>no MCL</i>	2010	7.61 mg / L
Manganese	0.05 mg/L	2010	< 0.01 mg / L
pH	6.5-8.5 S. U.	2008	7.7 S.U.
Silver	0.1 mg/L	2010	< 0.01 mg / L
Sodium	<i>no MCL</i>	2010	53.7 mg / L
Sulfate	250 mg/L	2008	11 mg / L
Total Alkalinity	<i>no MCL</i>	2008	198 mg / L
Total Dissolved Solids	500 mg/L	2008	281 mg / L
Total Hardness as CaCO ₃	<i>no MCL</i>	2010	134 mg / L
Zinc	5 mg/L	2010	0.0079 mg / L